

17 October 2016

43-47 Newton Rd  
Wetherill Park NSW 2164

Tridonic Australia Pty Ltd.

Dear Sir / Madam,

**APPROVAL OF NON-PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact David Eddy on telephone (03) 9203 9700, or email [deddy@esv.vic.gov.au](mailto:deddy@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



**DIRECTOR OF ENERGY SAFETY**

Ref: ESV160568/00

Certificate Number: ESV160568/00

# Certificate of Compliance

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Tridonic Australia Pty Ltd.  
43-47 Newton Rd  
Wetherill Park NSW 2164

**Authorised Marking:** ESV160568

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, may be clearly and indelibly marked with the marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification should be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Level 1 NP: Non-Prescribed Select constant current fixed output LED Driver: built-in type
Relevant Standards:	AS/NZS 61347.2.13:2013
Expiry Date:	14 October 2021
Conditions of Approval:	



Certificate Number: ESV160568/00



Creating a  
safer state with  
electricity and gas

## Approval details

Model	LC 38W 250-350mA flexC lp ADV
Rated at	Input: 220-240 V, 43 W, 50/60 Hz Output: 250 Vdc, 38 W, 250-350 mA
Trade Name	TRIDONIC
Comments	

Model	LC 38W 350-500mA flexC lp ADV
Rated at	Input: 220-240 V, 42.5 W, 50/60 Hz Output: 250 Vdc, 38 W, 350-500 mA
Trade Name	TRIDONIC
Comments	

Model	LC 53W 250-350mA flexC lp ADV
Rated at	Input: 220-240 V, 57 W, 50/60 Hz Output: 250 Vdc, 53 W, 250-350 mA
Trade Name	TRIDONIC
Comments	

Model	LC 69W 350-500mA flexC lp ADV
Rated at	Input: 220-240 V, 76.5 W, 50/60 Hz Output: 250 Vdc, 69 W, 350-500 mA
Trade Name	TRIDONIC
Comments	

Model	LC 71W 250-350mA flexC lp ADV
Rated at	Input: 220-240 V, 77 W, 50/60 Hz Output: 250 Vdc, 71 W, 250-350 mA
Trade Name	TRIDONIC
Comments	

DATE OF APPROVAL: 17 October  
2016


Page: (3 / 4)

Director of Energy Safety

Certificate Number: ESV160568/00



DATE OF APPROVAL: 17 October 2016 Page: (4/ 4)

  
Director of Energy Safety